



PSH

CERTIFICATE OF QUALITY

Test Certificate

CONFORMITY OF THE PRODUCT ACCORDING TO THE APPLICABLE REGULATIONS AND TO THE BOMBAS PSH QUALITY STANDARDS

Name and address of the applicant	A-TECHNOLOGIES FZCO PLOT NO: S20901 NEAR SUMMIT STEEL, SOUTH OZONE, P.O.BOX 18400, JABAL ALI FREEZONE, UAE
Product	Polypropylene pump (PP+30%GF) with plastic one piece impeller
Model	F-GIANT
Nominal rate and main characteristics	2900rpm – 50Hz – IE3 – IP55 F-GIANT-18 5.5 HP - 3x400/690V 63m ³ /h at 14m
Standards	Machinery Directive 2006/42/EC. Low Voltage Directive 2014/35/EU. Electromagnetic Compatibility Directive 2014/30/EU. Restrict of Hazardous Substances Directive (RoHS) Directive 2011/65/EU. Ecodesign Directive 2009/125/EC, in accordance with technical standard IEC 60034-30-1:2014. WEEE Directive 2012/19/EU.
Motor test	Ok
Assembly test	Ok
Balancing of the impeller	Ok
Pressure Decay test	Ok
Flow rate performance test	Not required

OFFICE

CARRER D'ANTONI DE BORJA, 7, ENTLO. 1ª
08191 RUBÍ (BARCELONA) SPAIN
INFO@BOMBASPSH.COM

FACTORY

CARRETERA DE MANRESA A BERGA, S/N
COLÒNIA TÈXTIL EL MOLÍ
08660 BALSARENY (BARCELONA) SPAIN