



ATECPOOL
INTERNACIONAL ESPAÑA

World Trade Center Edificio Sur
2^a Planta - Muelle de Barcelona
E-08039 Barcelona, **Spain**
(+34) 93 344 33 58
info@atecpool.com

The test certificate for Model 03300080 # 45 KW / 34 KW

The test condition when cooling			
Ambient temp(°c)	48°C	Water flow volume (m ³ /h)	14m ³ /h
Voltage (V)	380V	Running time (hrs)	48hrs
Water inlet temp (°C)	38°C	Water outlet temp(°C)	29°C
Testing data when cooling			
Test term	Unit	System 1	System 2
Running current	A	8.1 - 8 - 8.2	8.3 - 8.1 - 8.6
Low pressure	MPa	0.63	0.66
Compressor gas outlet temp.	°C	90	84
The test condition when heating			
Ambient temp(°c)	15°C	Water flow volume (m ³ /h)	14m ³ /h
Voltage (V)	380V	Running time (hrs)	48hrs
Water inlet temp (°C)	20°C	Water outlet temp(°C)	29°C
Testing data when heating			
Test term	Unit	System 1	System 2
Running current	A	7 - 7.2 - 7.5	7.3 - 7 - 7.4
Low pressure	MPa	0.61	0.6
Compressor gas outlet temp.	°C	68	69
Place: Lab 2#	Tester: Mr.Gary	Assessor: Mr.Mark	Result: Pass

