



ATECPOOL
INTERNACIONAL ESPAÑA

World Trade Center Edificio Sur
2^a Planta - Muelle de Barcelona
E-08039 Barcelona, **Spain**
(+34) 93 344 33 58
info@atecpool.com

The test certificate for Model 03310070 # 35 KW / 25 KW

The test condition when cooling			
Ambient temp(°c)	48°C	Water flow volume (m ³ /h)	10m ³ /h
Voltage (V)	380V	Running time (hrs)	48hrs
Water inlet temp (°C)	38°C	Water outlet temp(°C)	29°C
Testing data when cooling			
Test term	Unit	System 1	System 2
Running current	A	7.3 -7.1 - 7.5	7.5 - 7.7 - 7.9
Low pressure	MPa	0.66	0.67
Compressor gas outlet temp.	°C	84	88
The test condition when heating			
Ambient temp(°c)	15°C	Water flow volume (m ³ /h)	10m ³ /h
Voltage (V)	380V	Running time (hrs)	48hrs
Water inlet temp (°C)	20°C	Water outlet temp(°C)	29°C
Testing data when heating			
Test term	Unit	System 1	System 2
Running current	A	6.0 - 6.3 - 6.6	6.8 - 6.3 - 6.7
Low pressure	MPa	0.52	0.56
Compressor gas outlet temp.	°C	67	67
Place: Lab 2#	Tester: Mr.Gary	Assessor: Mr.Mark	Result: Pass

