



ATECPOOL
INTERNACIONAL ESPAÑA

World Trade Center Edificio Sur
2^a Planta - Muelle de Barcelona
E-08039 Barcelona, Spain
[+34] 93 344 33 58
info@atcpool.com

The test certificate for Model 03310110 # 90 KW / 70 KW

The test condition when cooling				
Ambient temp(°C)	48°C	Water flow volume (m³/h)	30m³/h	
Voltage (V)	380V	Running time (hrs)	48hrs	
Water inlet temp (°C)	38°C	Water outlet temp(°C)	29°C	
Testing data when cooling				
Test term	Unit	System 1	System 2	
Running current	A	18.6 - 18.2 - 19	18.4 - 18 - 18.6	
Low pressure	MPa	0.58	0.60	
Compressor gas outlet temp.	°C	84	81	
The test condition when heating				
Ambient temp(°C)	15°C	Water flow volume (m³/h)	30m³/h	
Voltage (V)	380V	Running time (hrs)	48hrs	
Water inlet temp (°C)	20°C	Water outlet temp(°C)	29°C	
Testing data when heating				
Test term	Unit	System 1	System 2	
Running current	A	20.4 - 20.2 - 19.4	20 - 20.8 - 19.4	
Low pressure	MPa	0.57	0.59	
Compressor gas outlet temp.	°C	65	67	
Place: Lab 2#	Tester: Mr.Gary	Assessor: Mr.Mark	Result:	Pass

